

No. CE/T-QC/MSC-I/Cable/

No 0 2 2 0 7

Date: 21 JAN 2025

To,  
M/s. Alfa Enterprises (Unique Cabcon),  
Plot no.7, Rajeev Nagar Industrial Estate,  
Pipalkhoriya Raisen, Bhopal, M.P-464551.

Contact No. 9827216295, 9960188858  
Email: [uniquecabcon@gmail.com](mailto:uniquecabcon@gmail.com)

Sub: Vendor approval for supply of LT Aerial Bunched cables under on-going MSEDCL scheme.

- Ref :-
- 1) This office circular no.CE/Testing/TTR-Validity/Circular/10 dtd. 22.06.2020.
  - 2) Office note F-2020011400/2020 approved on dt.08.01.2021 & F-2022006710/2022 approved on dt.12.07.2022
  - 3) Your online vendor registration
  - 4) Verification of original type test reports on dtd.15.01.2025.
  - 5) Approval from Competent Authority on dtd. 20.01.2025, Office Note no F-2025000645/2025.

Dear Sirs,

This office is in receipt of your proposal for vendor approval for supply of following size of LT Aerial Bunched cables under on-going MSEDCL schemes for following item.

- a) 3Cx95+1Cx16+1Cx70 sq.mm.
- b) 3Cx70+1Cx16+1Cx50 sq.mm.
- c) 3Cx50+1Cx16+1Cx35 sq.mm

The copies of the Type Test Reports submitted by your firms are verified with originals in presence of your firm's representative as below.

Sr. No.	Size Of Cable	Type test report & Date	Place of Testing
LT Aerial Bunched Cable			
1	3Cx50+1Cx16+1Cx35 sq.mm, Aerial Bunched Cable aluminum conductor ,XLPE Insulated, 1100V Grade	ELMEF/24/09/255/0004/EL-0001/III dtd.08.10.2024	ELMEF, Indore
		RTS/241004-L971 Dtd.04.10.2024	RTS, Rajasthan
2	3Cx70+1Cx16+1Cx50 sq.mm, Aerial Bunched Cable aluminum conductor ,XLPE Insulated, 1100V Grade.	ELMEF/24/09/255/0004/EL-0001/IV dtd.08.10.2024	ELMEF, Indore
		RTS/241004-L982 Dtd.05.10.2024	RTS, Rajasthan
3	3Cx95+1Cx16+1Cx70 sq.mm, Aerial Bunched Cable aluminum conductor ,XLPE Insulated 1100V Grade.	ELMEF/24/08/215/0001/EL-0001 dtd.30.08.2024	ELMEF, Indore
		RTS/241004-L972 Dtd.04.10.2024	RTS, Rajasthan

The proposal submitted by you is scrutinized in light of MSEDCL technical specifications and respective IS/ IEC amended up to date. The Type Test Reports (TTR) and Guaranteed Technical Parameters (GTP) are found generally in order.

M/s. Alfa Enterprises (Unique Cabcon), – Vendor approval for supply of LT Aerial Bunched cables under on-going MSEDCL scheme

In view of above your proposal for supply of above sizes/ratings of LT Aerial Bunched cables is accepted & pleased to accord approval as MSEDCL approved vendor under on-going MSEDCL scheme.

This vendor approval is subject to following terms & conditions:

1. All routine and acceptance tests shall be carried out on all drums of above sizes/ratings LT Aerial Bunched cables as per relevant IS/ IEC (amended up to date) at your factory in presence of concerned Executive Engineer (Testing Division), MSEDCL.
2. This approval shall not be considered for any technical / commercial evaluation of any tender in MSEDCL.
3. The performance guarantee of 60 months from date of commissioning of offered sizes/ratings LT Aerial Bunched cables towards any manufacturing defect shall be given to the end customer.
4. You have to maintain same design & construction of all above sizes/ratings LT Aerial Bunched cables strictly in accordance with the approved GTPs and MSEDCL technical specifications and respective IS / IEC (amended up to date) only.
5. The testing and inspection procedure as given in the MSEDCL technical specification shall be adopted scrupulously.
6. The approval of GTPs shall not relieve you from responsibilities and liabilities to ensure correctness of drawings & correct interpretation for meeting requirements as per technical specifications and respective IS / IEC.
7. All other technical parameters of all above sizes/ratings LT Aerial Bunched cables should be strictly in accordance with the technical specifications & respective IS / IEC (amended up to date).
8. **This vendor approval is valid for TWO years i.e. up to dtd.21.01.2027 and it should be ensured by inspecting officer at the time of inspection.**

This approval is issued and without prejudice to technical specifications and all the terms and conditions of the all other tender.

Thanking You.

Encls: One set of approved GTP duly signed & stamped.

Yours Sincerely,



Dr. M. G. Wath  
Chief Engineer (Testing-QC)  
MSEDCL, Mumbai.

Copy s.w.rs.to:

- 1) Director (Projects) / (Operations), MSEDCL, Prakashgad, Mumbai.
- 2) Executive Director-II (Dist.)/ (Infra)/ (Projects), MSEDCL, Prakashgad, Mumbai.

Copy f.w.cs. to:

- 1) Chief Engineer (O&M), All Zones, MSEDCL.
- 2) Chief Engineer, (MMD)/(HVDS)/(Projects)/(SP)/(Dist.), MSEDCL, Prakashgad, Mumbai.

Copy to:

- 1) Superintending Engineer, (Infra) / (MSC), MSEDCL, Prakashgad, Mumbai.
- 2) Superintending Engineer (O&M), All Circles, MSEDCL.